

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3775-0257:113

Page 1 of 1

CATEGORY: Manual Locks

LISTEE: Yale, 1902 Airport Rd., Monroe, NC 28110
Contact: *Jeff Trull (704) 283-2101

DESIGN: Models 5235, 5237, 5301 through 5316, 5320, 5321, 5322, 5325, 5328, 5329, 5331, 5332 and 5335, with or without suffix ALN≡, equipped with 2" latch bolts having right and left hand regular and reverse bevels.

Models 5401 through 5423, 5425, 5428, 5430, 5501 through 5523, 5525, 5528 and 5530, equipped with 2", 5/8" and 3/4" latch bolts having right and left hand, regular and reverse bevels.

Models 5701 through 5716, 5720, 5722, 5725, 5728, 5731, 5732 and 5735 with 2" latch bolts having right and left hand regular and reverse bevels.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as single point locks or latches for use in swinging fire doors of hollow metal, metal clad, composite, wood core and sheet metal types.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager